



NEGARA BRUNEI DARUSSALAM

**BRUNEI DARUSSALAM STANDARD
PIAWAI BRUNEI DARUSSALAM**

**PBD IEC 60364-5-52: 2010
IEC 60364-5-52: 2010
Edition 3.0**

**LOW-VOLTAGE ELECTRICAL INSTALLATIONS -
PART 5-52: SELECTION AND ERECTION OF ELECTRICAL
EQUIPMENT - WIRING SYSTEMS**

**ENERGY DIVISION, PRIME MINISTER'S OFFICE
IN COLLABORATION WITH MINISTRY OF DEVELOPMENT
NEGARA BRUNEI DARUSSALAM**

FOREWORD

This Brunei Darussalam Electrical Standard was prepared by the Technical Committee on Electrical Standards (TECO), Energy Division at Prime Minister's Office in collaboration with the Authority for Building and Construction Industry (ABCI), Ministry of Development, Brunei Darussalam with the objective of developing the National Electrical Standards for electrical products, systems, equipments and facilities for the local industry and consumers with reference to international standards, guidelines and procedures. In developing the national electrical standards, the aim is to promote quality, technical integrity, health, safety and environmental standards for the local industries and consumers.

This Brunei Darussalam Electrical Standard is an adoption of the International Electro Technical Commission IEC 60364-5-52: 2001 (Edition 3) standard and implements it as the Brunei Darussalam National Standard.

Attention is drawn to the fact that this Brunei Darussalam Electrical Standard does not confer any immunity from legal obligations in any contract for compliance to the Standard.

The National Electrical Standards are subject to periodical review according to the current needs of the local industries and consumers to keep abreast of progress in the industries and consumers concerned. Suggestions of amendments will be recorded and in due course brought to the notice of the committees concerned.

COMMITTEE MEMBERS

The Technical Committee on Electrical Standards (TECO) was tasked by the Energy Division at the Prime Minister's Office in collaboration with the Authority for Building and Construction Industry (ABCI), Ministry of Development, Brunei Darussalam for the preparation of this Brunei Darussalam Electrical Standard. The members of the Technical Committee are as follows:

1. Awg Haji Abd Shawal Yaman
(Chairman) Department of Electrical Services, PMO
2. Awg Liaw Wai Khiong
(Co-Chairman) Brunei Shell Petroleum Co. Sdn Bhd /
Institution of Engineering and Technology,
Brunei Darussalam
3. Pg Shaharuddin Pg Haji Yusoff
(Secretary) ABCi, Ministry of Development
4. Awg William Voon
(Assistant Secretary 1) Berakas Power Management Company,
5. Awg Simon K A Leong
(Assistant Secretary 2) KR Kamarulzaman & Associates
6. Awg Haji Md Azrul Azrin Hj Md Zain Department of Electrical Services, PMO
7. Awg Md Amir Sharifuddin Haji Ali Department of Electrical Services, PMO
8. Awg Khairul Ezam Hj Mohd Zain ABCi, Ministry of Development
9. Awg Dennis Wong Tet Yin Department of Mechanical & Electrical
Services, PWD
10. Awg Nohi Irwan Surkarki Haji Pawi Department of Fire & Rescue Services
11. Awg Haji Morsidi Haji Kassim Institut Teknologi Brunei
12. Awg Haji Ismit Haji Mohamad Institut Teknologi Brunei
13. Awg Matyassin Haji Masri Maktab Kejuruteraan Jefri Bolkiah
14. Awg Sylvester Kong Brunei Shell Petroleum Co. Sdn Bhd
15. Dyg Seri Malati OKIP Hj Zolkeflee Brunei Shell Petroleum Co. Sdn Bhd
16. Awang Aristoteles Momin Brunei LNG Sdn Bhd
17. Awg Rick Liaw Hamzah Hassan Consultant

SUB-COMMITTEE NO. 5 MEMBERS

The Sub-Committee No. 5 (SC5) is the working groups for the Electrical Wiring Code of Practice who assisted in the preparation for the adoption of the Brunei Darussalam Electrical Standard. The members of the Sub-Committee No. 5 are :

- | | |
|---------------------------------------|---|
| 1. Awg William Voon
(Chairman) | Berakas Power Management Company, |
| 2. Awg Liaw Wai Khiong
(Secretary) | Brunei Shell Petroleum Co. Sdn Bhd
Institution of Engineering and Technology,
Brunei Darussalam |
| 3. Pg Shahrudin Pg Haji Yusoff | ABCI, Ministry of Development |
| 4. Awg Khairul Ezam Hj Mohd Zain | ABCI, Ministry of Development |
| 5. Awg Simon K A Leong | KR Kamarulzaman & Associates |
| 6. Awg Dennis Wong Tet Yin | Department of Mechanical & Electrical
Services, PWD |
| 7. Dr Rohaniyati Salleh | Department of Mechanical & Electrical
Services, PWD |
| 8. Dyg Hajah Norhayati binti Ahmad | Department of Electrical Services, PMO |
| 9. Awg Abdul Azia bin Abdullah | Department of Electrical Services, PMO |
| 10. Awg Matyassin Haji Masri | Institut Teknologi Brunei |
| 11. Awg Haji Morsidi Haji Kassim | Maktab Kejuruteraan Jefri Bolkiah |
| 12. Awg Tony Ng | PKS Sdn Bhd |
| 13. Awg N. Sivakumar | LKH (B) Sdn Bhd |
| 14. Awg Tan Tau Minn | SEC Mashibah Sdn Bhd |



IEC 60364-5-52

Edition 3.0 2009-10

PIAWAI BRUNEI DARUSSALAM – BRUNEI DARUSSALAM STANDARD

INTERNATIONAL STANDARD

**Low-voltage electrical installations –
Part 5-52: Selection and erection of electrical equipment – Wiring systems**

IEC 60364-5-52:2009

**PBD IEC 60364-5-52: 2010 (Published by IEC in 2009)
This IEC International Standard has been adopted by CPRU, Ministry of Development,
Negara Brunei Darussalam as a national standard under the IEC Affiliate Country Programme**

CONTENTS

FOREWORD 6

520 Introduction 8

 520.1 Scope 8

 520.2 Normative references 8

 520.3 Terms and definitions 9

 520.4 General 9

521 Types of wiring system 10

 521.4 Busbar trunking systems and powertrack systems 10

 521.5 AC circuits – Electromagnetic effects (prevention of eddy current) 10

 521.6 Conduit systems, cable ducting systems, cable trunking systems, cable tray systems and cable ladder systems 10

 521.7 Several circuits in one cable 11

 521.8 Circuit arrangements 11

 521.9 Use of flexible cables or cords 11

 521.10 Installation of cables 11

522 Selection and erection of wiring systems in relation to external influences 11

 522.1 Ambient temperature (AA) 11

 522.2 External heat sources 12

 522.3 Presence of water (AD) or high humidity (AB) 12

 522.4 Presence of solid foreign bodies (AE) 12

 522.5 Presence of corrosive or polluting substances (AF) 13

 522.6 Impact (AG) 13

 522.7 Vibration (AH) 13

 522.8 Other mechanical stresses (AJ) 13

 522.9 Presence of flora and/or mould growth (AK) 15

 522.10 Presence of fauna (AL) 15

 522.11 Solar radiation (AN) and ultraviolet radiation 15

 522.12 Seismic effects (AP) 15

 522.13 Wind (AR) 15

 522.14 Nature of processed or stored materials (BE) 15

 522.15 Building design (CB) 15

523 Current-carrying capacities 16

 523.5 Groups containing more than one circuit 17

 523.6 Number of loaded conductors 17

 523.7 Conductors in parallel 17

 523.8 Variation of installation conditions along a route 18

 523.9 Single-core cables with a metallic covering 18

524 Cross-sectional areas of conductors 18

 524.2 Cross-sectional area of the neutral conductor 19

525 Voltage drop in consumers' installations 20

526 Electrical connections 20

 526.8 Connection of multi wire, fine wire and very fine wire conductors 21

527 Selection and erection of wiring systems to minimize the spread of fire 21

 527.1 Precautions within a fire-segregated compartment 21

 527.2 Sealing of wiring system penetrations 22

528 Proximity of wiring systems to other services 23

528.1 Proximity to electrical services.....	23
528.2 Proximity of communications cables	23
528.3 Proximity to non-electrical services.....	23
529 Selection and erection of wiring systems in relation to maintainability, including cleaning.....	24
Annex A (normative) Methods of installations.....	25
Annex B (informative) Current-carrying capacities	34
Annex C (informative) Example of a method of simplification of the tables of Clause 523	63
Annex D (informative) Formulae to express current-carrying capacities	67
Annex E (normative) Effect of harmonic currents on balanced three-phase systems	71
Annex F (informative) Selection of conduit systems	73
Annex G (informative) Voltage drop in consumers' installations	74
Annex H (informative) Examples of configurations of parallel cables.....	76
Annex I (informative) List of notes concerning certain countries.....	79
Bibliography.....	84
Figure H.52.1 – Special configuration for 6 parallel single-core cables in a flat plane (see 523.7)	76
Figure H.52.2 – Special configuration for 6 parallel single-core cables above each other (see 523.7)	76
Figure H.52.3 – Special configuration for 6 parallel single-core cables in trefoil (see 523.7)	77
Figure H.52.4 – Special configuration for 9 parallel single-core cables in a flat plane (see 523.7)	77
Figure H.52.5 – Special configuration for 9 parallel single-core cables above each other (see 523.7)	77
Figure H.52.6 – Special configuration for 9 parallel single-core cables in trefoil (see 523.7)	78
Figure H.52.7 – Special configuration for 12 parallel single-core cables in a flat plane (see 523.7)	78
Figure H.52.8 – Special configuration for 12 parallel single-core cables above each other (see 523.7)	78
Figure H.52.9 – Special configuration for 12 parallel single-core cables in trefoil (see 523.7)	78
Table 52.1 – Maximum operating temperatures for types of insulation	16
Table 52.2 – Minimum cross-sectional area of conductors	19
Table A.52.1 – Methods of installation in relation to conductors and cables	25
Table A.52.2 – Erection of wiring systems.....	26
Table A.52.3 – Examples of methods of installation providing instructions for obtaining current-carrying capacity	27
Table B.52.1 – Schedule of reference methods of installation which form the basis of the tabulated current-carrying capacities.....	39
Table B.52.2 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – PVC insulation/two loaded conductors, copper or aluminium – Conductor temperature: 70 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	41

Table B.52.3 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – XLPE or EPR insulation, two loaded conductors/copper or aluminium – Conductor temperature: 90 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	42
Table B.52.4 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – PVC insulation, three loaded conductors/copper or aluminium – Conductor temperature: 70 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	43
Table B.52.5 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – XLPE or EPR insulation, three loaded conductors/copper or aluminium – Conductor temperature: 90 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	44
Table B.52.6 – Current-carrying capacities in amperes for installation method C of Table B.52.1 – Mineral insulation, copper conductors and sheath – PVC covered or bare exposed to touch (see note 2) Metallic sheath temperature: 70 °C, reference ambient temperature: 30 °C	45
Table B.52.7 – Current-carrying capacities in amperes for installation method C of Table B.52.1 – Mineral insulation, copper conductors and sheath – Bare cable not exposed to touch and not in contact with combustible material Metallic sheath temperature: 105 °C, reference ambient temperature: 30 °C	46
Table B.52.8 – Current-carrying capacities in ampères for installation methods E, F and G of Table B.52.1 – Mineral insulation, copper conductors and sheath/PVC covered or bare exposed to touch (see note 2) Metallic sheath temperature: 70 °C, reference ambient temperature: 30 °C	47
Table B.52.9 – Current-carrying capacities in ampères for installation methods E, F and G of Table B.52.1 – Mineral insulation, copper conductors and sheath – Bare cable not exposed to touch (see note 2) Metallic sheath temperature: 105 °C, reference ambient temperature: 30 °C	48
Table B.52.10 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – PVC insulation, copper conductors – Conductor temperature: 70 °C, reference ambient temperature: 30 °C.....	49
Table B.52.11 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – PVC insulation, aluminium conductors – Conductor temperature: 70 °C, reference ambient temperature: 30 °C.....	50
Table B.52.12 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – XLPE or EPR insulation, copper conductors – Conductor temperature: 90 °C, reference ambient temperature: 30 °C.....	51
Table B.52.13 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – XLPE or EPR insulation, aluminium conductors Conductor temperature: 90 °C, reference ambient temperature: 30 °C.....	52
Table B.52.14 – Correction factor for ambient air temperatures other than 30 °C to be applied to the current-carrying capacities for cables in the air.....	53
Table B.52.15 – Correction factors for ambient ground temperatures other than 20 °C to be applied to the current-carrying capacities for cables in ducts in the ground	54
Table B.52.16 – Correction factors for cables buried direct in the ground or in buried ducts for soil thermal resistivities other than 2,5 K·m/W to be applied to the current-carrying capacities for reference method D.....	54
Table B.52.17 – Reduction factors for one circuit or one multi-core cable or for a group of more than one circuit, or more than one multi-core cable, to be used with current-carrying capacities of Tables B.52.2 to B.52.13	55
Table B.52.18 – Reduction factors for more than one circuit, cables laid directly in the ground – Installation method D2 in Tables B.52.2 to B.52.5 – Single-core or multi-core cables.....	56
Table B.52.19 – Reduction factors for more than one circuit, cables laid in ducts in the ground – Installation method D1 in Tables B.52.2 to B.52.5	57

Table B.52.20 – Reduction factors for group of more than one multi-core cable to be applied to reference current-carrying capacities for multi-core cables in free air – Method of installation E in Tables B.52.8 to B.52.13	59
Table B.52.21 – Reduction factors for groups of one or more circuits of single-core cables to be applied to reference current-carrying capacity for one circuit of single-core cables in free air – Method of installation F in Tables B.52.8 to B.52.13.....	61
Table C.52.1 – Current-carrying capacity in amperes.....	64
Table C.52.2 – Current-carrying capacities in amperes	65
Table C.52.3 – Reduction factors for groups of several circuits or of several multi-core cables (to be used with current-carrying capacities of Table C.52.1)	66
Table D.52.1 – Table of coefficients and exponents	68
Table E.52.1 – Reduction factors for harmonic currents in four-core and five-core cables.....	72
Table F.52.1 – Suggested characteristics for conduit (classification according to IEC 61386)	73
Table G.52.1 – Voltage drop	74

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS -

Part 5-52: Selection and erection of electrical equipment --
Wiring systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60364-5-52 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This third edition cancels and replaces the second edition, published in 2001, and constitutes a technical revision.

The main changes with respect to the previous edition are as follows:

- Subclause 521.4 introduces minor changes with regard to busbar trunking systems and powertrack systems.
- Subclause 523.6 introduces minor changes with regard to the sizing of cables where harmonic currents are present.
- A new subclause 523.9 concerning single-core cables with a metallic covering has been introduced.

- Clause 525 introduces changes in the maximum value of voltage drop permitted between the origin of the consumer's installation and the equipment which should not be greater than that given in the relevant annex.
- Clause 526 introduces minor changes to electrical connections including additional exceptions for inspection of connections and additional notes.
- Clause 528 introduces additional requirements with regard to proximity of underground power and telecommunication cables.
- Clause 529 introduces minor changes to selection and erection of wiring systems in relation to maintainability, including cleaning.

The text of this standard is based on the following documents:

FDIS	Report on voting
64/1685/FDIS	64/1705/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex I lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this standard.

A list of all the parts in the IEC 602364 series, under the general title *Low-voltage electrical installations*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 5-52: Selection and erection of electrical equipment – Wiring systems

520 Introduction

520.1 Scope

Part 5-52 of IEC 60364 deals with the selection and erection of wiring systems.

NOTE 1 This standard also applies in general to protective conductors, while IEC 60364-5-54 contains further requirements for those conductors.

NOTE 2 Guidance on Part 5-52 of IEC 60364 is given in IEC 61200-52.

520.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60228, *Conductors of insulated cables*

IEC 60287 (all parts), *Electric cables – Calculation of the current rating*

IEC 60287-2-1, *Electric cables – Calculation of the current rating – Part 2-1: Thermal resistance – Calculation of thermal resistance*¹

IEC 60287-3-1, *Electric cables – Calculation of the current rating – Part 3-1: Sections on operating conditions – Reference operating conditions and selection of cable type*²

IEC 60332-1-1, *Tests on electric and optical fibre cables under fire conditions – Part 1-1: Test for vertical flame propagation for a single insulated wire or cable – Apparatus*

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60364-1:2005, *Low-voltage electrical installations – Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-4-42, *Electrical installations of buildings – Part 4-42: Protection for safety – Protection against thermal effects*

¹ A consolidated edition 1.2 exists (2006) that includes IEC 60287-2-1 (1994) and its amendments 1 and 2 (1999 and 2006).

² A consolidated edition 1.1 exists (1999) that includes IEC 60287-3-1 (1995) and its amendment 1 (1999).